



State of Utah

Gary R. Herbert
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF DRINKING WATER
Marie E. Owens, P.E.
Director

August 31, 2018

Roy McDaniel
Aspen Crest Girls Camp
50 E North Temple Street
Natural Resource Services, Rm 1205
Salt Lake City UT 84150

Subject: Required to Disinfect, Aspen Crest Girls Camp, Water System #UTAH26012

Dear Mr. McDaniel,

The Division of Drinking Water (the Division) records indicate that you are the responsible party for the Aspen Crest Girls Camp Water System (the System).

The Aspen Crest Girls Camp System is a public water system and thus subject to the Administrative Rules for Public Drinking Water Systems (copy available upon request). Under Utah Administrative Code R309-100-4 a water system is considered to be a public water system when 25 or more people are served water for at least 60 days, or when the water system serves 15 or more water system connections.

Aspen Crest Girls Camp had Total Coliform positive (TC+) samples collected from the distribution system August 1995, June 2000, September 2000, August 2001, June 2014, July 2015, and August 2015. The system started chlorinating and collecting source samples from the Stewart Ranch Spring, WS001 in July 2015. The source samples were TC+ in July 2015, August 2015, November 2015, August 2016, May 2017, June 2017, and May 2018. (The system is only open June, July and August.) **Based on the sample history of this source, the Division of Drinking Water Director now requires your system to add continuous disinfection.**

Failure to meet this requirement by June 30, 2019 will be in violation of Section R309-215-5 of the Rules. A total of 50 IPS points will be assessed for this deficiency if not completed by June 30, 2019. You may request a Corrective Action Plan to extend the deadline by filling out the request form at requestcap.utah.gov or contact Brandi Smith at brandismith@utah.gov.


If you do not have an approved disinfection facility, the Division's Permitting Section is available

Roy McDaniel
Page 2
August 31, 2018

to assist your system in gaining plan approval and an operating permit for the required disinfection facilities. A project notification form is enclosed. You may contact Nathan Lunstad, Permitting Section Manager, for assistance at 385-239-5974, or nlunstad@utah.gov.

If you have any questions or wish to review the water system on-site please call **Janet Lee at 801-536-0088, or jjlee@utah.gov**.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marie E. Owens", with a large, stylized flourish extending to the right.

Marie E. Owens, P.E., Director
Division of Drinking Water

jl

Attachments

cc: Marie E. Owens, P.E., Director, Division of Drinking Water
Bret F. Randall, Assistant Attorney General
Dwight Hill, Wasatch County Local Health Department
Janet Lee, Division of Drinking Water
Randi Ryan, Division of Drinking Water
Nathan Lunstad, Division of Drinking Water